

SIMULATION OF RADIATION BACKGROUNDS ASSOCIATED WITH NUCLEAR DIAGNOSTICS IN THE NATIONAL IGNITION FACILITY

H. Khater, L. Dauffy, R. Tommasini, M. Eckart, D. Eder

August 21, 2009

The 6th International Conference on Inertial Fusion Sciences and Applications 2009
San Francisco, CA, United States
September 6, 2009 through September 11, 2009

Disclaimer

This document was prepared as an account of work sponsored by an agency of the United States government. Neither the United States government nor Lawrence Livermore National Security, LLC, nor any of their employees makes any warranty, expressed or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States government or Lawrence Livermore National Security, LLC. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States government or Lawrence Livermore National Security, LLC, and shall not be used for advertising or product endorsement purposes.

Simulation of Radiation Backgrounds Associated with Nuclear Diagnostics in the National Ignition Facility


■ Abstract

Experiments resulting in a significant neutron yield are scheduled to start in 2010 at the National Ignition Facility (NIF). Several experiments utilizing Tritium-Hydrogen-Deuterium (THD) and Deuterium-Tritium (DT) targets are scheduled as part of the National Ignition Campaign (NIC). A wide range of diagnostics will be used to measure several parameters of implosion such as the core and fuel shape, temperatures and densities, and neutron yield. Accurate evaluations of the neutron and gamma backgrounds are important for several diagnostics, such as the High Energy X-ray Imager (HEXRI) and Neutron-Time-Of-Flight (nTOF). Several sources of neutron and gamma backgrounds will impact the accuracy of the diagnostics measurements. Fusion neutrons generated by fuel burn and secondary neutrons resulting from the fusion neutrons' interaction with structures present inside and outside the Target Chamber (TC) contribute to the neutron background. In the meantime, X-rays emitted from the implosion, X-rays resulting from Laser Plasma Interaction (LPI) of NIF beams with the hohlraum, and gamma-rays induced by neutron interactions with different structures inside and outside the TC contribute to the gamma background. A detailed model has been developed of the NIF facility and all structures inside the TC. Several Monte-Carlo simulations were performed to identify the expected signal-to- background ratios at several potential locations for the HEXRI and nTOF diagnostics. Gamma backgrounds associated with HEXRI were significantly reduced by using a tungsten collimator. The collimator resulted in the reduction of the gamma background at the HEXRI scintillator by more than an order of magnitude during the first 40 ns following a THD shot. The nTOF20 detectors inside the Neutron Spectrometry room are exposed to low levels of neutron and gamma background during yield shots.

Simulation of Neutron and Gamma Backgrounds for the NIF Diagnostics


- · Experiments utilizing Tritium-Hydrogen-Deuterium (THD) and Deuterium-Tritium (DT) targets are scheduled as part of the National Ignition Campaign (NIC)
- · A wide range of diagnostics will be used to measure several parameters of implosion such as the core and fuel shape, temperatures and densities, and
- The High-Energy X-Ray Imager (HEXRI) will be used on cryogenic DT implosions at NIF to provide data on the size and shape of the
- The neutron time-of-flight (nTOF) diagnostic will measure ion temperature, absolute and relative yields of primary and downscattered neutrons, and
- Following an implosion, the background from neutrons and gamma can affect the quality of HEXRI images and the nTOF detector response in terms of lowering the signal-to-background ratio

Modeling of the NIF Facility




Target Chamber with Potential Locations of Ignition/Implosion Diagnostics

3-D Model of Target Bay




H. Y. Khater, L. S. Dauffy, R. Tommasini, M. J. Eckart, and D. C. Eder **Lawrence Livermore National Laboratory**


Modeling of Masses near TCC




HEXRI Detector Setup




Map of Neutron Fluence during First 40 ns




Map of Gamma Fluence during First 40 ns




HEXRI Gamma Spectrum due to (n,γ) Reactions




Gamma Background-to-Signal Ratio




Contribution to the Gamma **Background without Collimators**




Layout of the nTOF20 at (114.5,319)






Neutron Fluence outside TB Wall




~ 3 orders of magnitud





Gamma Dose in the NS Room during Yield Shots



Summary


- Detailed simulation of the radiation environment in NIF allowed for good understanding of the important issues related to performance of several proposed nuclear diagnostics
- Development of models that include important details relevant to the different NIF diagnostics is underway
- Accurate simulation of neutron and gamma backgrounds are essential for success of nuclear diagnostics used during the ignition campaign
- The use of tungsten collimators reduced the gamma background experienced by HEXRI detectors by more than an order of magnitude during THD shots
- TARPOS and CRYO TARPOS are the largest contributors to the **HEXRI** gamma background
- The nTOF20 detectors inside the Neutron Spectrometry room at -21'-9" are exposed to low levels of neutron and gamma backgrounds during yield shots
- Careful placement of electronics racks inside the Neutron Spectrometry room will minimize their exposure to radiation background during yield shots

Gamma Fluence outside TB Wall at 22.32 m

at 22.32 m

measurement by

nTOF detectors



per 14 MeV

√ 13 diagnostic penetrations

